

SCHEDULE OF QUANTITIES OF LIFTS For (Publication Department, G: Ramsar Sahib, Sri Amritsar)					
S. No.	Description	Unit	Qty.	Rate	Amount
1	Providing erecting, testing and commission goods/passenger lift with machine room on top in existing well including necessary scaffolding etc. as per the specifications complete in all respects.	NO	1		
	Approved makes KONE MITSUBISHI, HITACHI, OTIS, SCHNIDLER.				
	No of Landings	6 (Six), B+G+I+II+III+IV (All on the same side)			
	Travel Ht.	20 Mtr (Approx.)			
	Stop	6 Stop, 6 Opening			
	Overhead Ht.	4300mm			
	Capacity	1000 Kg.			
	Speed	1 mtrs./Sec.			
	Type of Lift	Electrically Operated (As per standard of IS: 14665)			
	Type of Machine	Geared, mounted at the top of the lift shaft			
	Guide Rail	Machined, T-Type			
	Size of Cabin	1800mm X 1700mm (Approx.)			
	Shaft Size	2900mm X 2167mm (Approx.)			
	Type of Cabin	S.S (304) Hair Line finish cabin panels with false ceiling, Fan & LED Lights			
	Flooring	M.S. Checkered			
	Type of Doors	Manual Bi-Parting/Automatic Bi-Parting			
	Door Opening	1700mm X 2000mm height (Approx.) with glass panel one side at Ground Floor.			
	Rope	Make "Usha Martin"			
	Display	Digital Display Direction & Landing Display both in car & at all landings on Stainless Steel Plates.			
	Driving Unit	Make Elecon/Heena/Sharp			
	Gear Box	Worm Reduction			
	Brake	Electro-Magnetic (D.C.)			
	Motor	5.5 KW			
	Power Supply	3 Phase with neutral, 415 Volts, 50 Hz			
	Control Panel	Consisting of contactors & M.C.B., (Siemens/L&T/BCH/ABB/Tele-Mec France) Controlled by 24/110 Volts. With VFD make Yaskawa.			



Shiromani Gurdwara Parbandhak Committee, Sri Amritsar,



Teja Singh Samundri Hall, Sri Amritsar.

	Other Features	L.E.D. based buttons		
		Battery operated emergency alarm with rechargeable battery.		
		Platform of cabin is constructed out of rolled formed sheets of steel.		
		Door open announcement system will be provided in case of door/s remains open.		
		Advance Door Opening.		
		Door open/close buttons.		
		Over load by-pass function.		
		Load weighing device		
		Voltage stabilizer for control system		
		Automatic Rescue Device to make lift open on lower floor in case of power failure.		
	Safety Features	Spring Buffers will be provided in the pit.		
		Limit Switches/sensor will be provided for each landing.		
		Double limit switches will be provided at the top & bottom for extra safety.		
		Over speed Governer brake will be provided for extra safety.		
		EMERGENCY STOP button will be provided in the cabin.		
		All the doors will be interlocked with the control panel.		
	Please note that the cost of the lift quoted here is inclusive of a warranty for 2 years.			
	All inclusive comprehensive Annual maintenance contract of 5 years after expiry of warranty. The rate quoted shall be payable in 5 annual equitable installments. The contractor shall provide a bank guarantee of the same amount to the S.G.P.C. for 5 years. The contractor is free to quote any competitive rate however the performance bank guarantee shall be for a minimum value of Rs. 10,00,000 for each lift.			

Expression of Interest

Advertisement No:- Ad/10-1/E/15-16

Tender Notice

S.G.P.C., Sri Amritsar Invites tender from approved & eligible firms for Providing erecting, testing and commission passenger & goods lift with or without machine room on top in existing well including necessary scaffolding etc. as per the specifications complete in all respects for the following sites.

- 1) Sri Guru Hargobind Niwas, The Golden Temple, Sri Amritsar.
- 2) Publication Department, G: Ramsar Sahib, Sri Amritsar.

Sealed Tenders duly filled should be deposited at Sub office, Kothi No 30, Sector 5-A, Chandigarh on 24-08-2015 by 11:00 AM. Tenders shall be opened on same day 12.00 PM in the Sub office, Chandigarh in the presence of the Bidders or their authorized representative(s) who may wish to be present.

Interested firms can download complete specifications, condition and details of lifts from our website i.e. www.sgpc.net

Secretary (Construction),
Shiromani Gurdwara Parbandhak Committee,
Sri Amritsar

⚔ Shiromani Gurdwara Parbandhak Committee, Sri Amritsar, ⚔

Teja Singh Samundri Hall, Sri Amritsar.