



SCHEDULE OF QUANTITIES OF LIFTS (Bhai Bachitar Singh Ji Niwas, Takhat Sri Kesgarh Sahib, Sri Anandpur)					
S.No	Description	Unit	Qty.	Rate	Amount
1	Providing, erecting, testing and commissioning passenger lift without machine room on top in existing well including necessary scaffolding, electrical wiring, minor civil works, conduiting etc. as per the following specifications complete in all respects.	No	2		
	Approved makes KONE MITSUBISHI, HITACHI, OTIS, SCHNIDLER.				
	Weight	Min 1088 Kg. (16 persons)			
	Speed	Min 1.50 MPS			
	Travel (Max) - Mts.	23.00 Mtrs. approx			
	Stops & Openings(Max)	06 stops, Basement+G+4, (same Side opening)			
	Control Operation	AC variable voltage variable frequency with Simplex full collective with or without Attendant/Automatic.			
	Machine	Gear less synchronous Magnet /Traction Motor to be hoisted on the guide rail/on top of the lift car			
	Shaft Size	2150 x 2425mm			
	Door Openings	Automatic centre opening 900 mm wide scratch resistant finish stainless steel on both sides internal and external side (with centre glass panel one side on ground floor) with automatic DC/VF door opening with adjustable opening and closing timing including provision of emergency key openings at all landings. The door frames, sills, fascia plates and al visible components shall be in the same finish as the door.			
	Car Enclosure	Scratch resistant finish stain-less steel panels, Stainless steel handles running the entire perimeter on three sides inside the car.			
	Flooring	Black Granite			
	Ceiling	Diffused fluorescent light with external fan with stainless steel ceiling on top			
	Operating Panels	Integrated full height car operation panel with luminous buttons, digital car position indicators combined with direction arrows, overload warning indicator and service cabinet, battery operated alarm bell and emergency light fireman switch at ground floor combined luminous hall buttons and digital hall position indicators at al floors Al indicators in brush stainless steel flush plates & vandal proof			
	NOISE LEVEL IN CABIN (RUNNING CAR)	55 db(A)			
	COOLING IN ELEVATOR	BLOWER MOUNTED ON ROOF WITH 2 SIDE DUCTS.			
	Features	* Battery operated Emergency alarm with rechargeable battery			
		* hands free press & speak Intercom			
		* Infrared safety curtain along full length of door			
		* Battery operated Emergency light with rechargeable battery			





Shiromani Gurdwara Parbandhak Committee, Sri Amritsar,



Teja Singh Samundri Hall, Sri Amritsar.

		Automatic phase reversal device				
		Call registration on buttons with braille				
		System capable of withstanding voltage variations of +/- 10% in supply voltage				
		* Advance Door opening				
		* Stuck push button supervision				
		* Car Call Backwards				
		* Door open/close buttons				
		* Landing call disconnect switch				
		* Over load by-pass function				
		* Manually operated Rescue Device				
		* Fireman Drive				
		Pit ladder				
		Fireman switch at main lobby				
		Heavy duty door operators				
		Additional car gate locks				
		* Phase failure detection				
		* Load weighing device				
		* Correction drive				
		* Voltage stabilizer for control system				
		* Automatic Rescue Device to make lift open on lower floor in case of power failure.				
	Please note that the cost of the lift quoted here is inclusive of a warranty for 2 years.					
2	All inclusive Comprehensive Annual maintenance contract of 5 years after expiry of warranty. The rate quoted shall be payable in 5 annual equitable installments. The contractor shall provide a bank guarantee of the same amount to the SGPC for 5 years. The contractor is free to quote any competitive rate however the bank guarantee shall be for a minimum value of Rs 10,00,000 for each lift					

 **Shiromani Gurdwara Parbandhak Committee, Sri Amritsar,** 

Teja Singh Samundri Hall, Sri Amritsar.

Expression of Interest

Advertisement No:- Ad/10-1/E/17-01

Tender Notice

S.G.P.C., Sri Amritsar Invites tender from approved & eligible firms for Providing erecting, testing and commission passenger & goods lift with or without machine room on top in existing well including necessary scaffolding etc. as per the specifications complete in all respects for the following sites.

- 1) **Bhai Bachitar Singh Ji Niwas, Takhat Sri Kesgarh Sahib, Sri Anandpur Sahib (Ropar).**
- 2) **Langar Sri Guru Ramdas Ji, Sachkhand Sri Harmandir Sahib, Sri Darbar Sahib, Sri Amritsar..**

Sealed Tenders duly filled should be submitted in the office of Secretary, S.G.P.C, Teja Singh Samundari Hall, Sri Amritsar on dt. 26-06-2017 by 11:00 Am. Tenders shall be opened on same day 12.00 PM in the Admin Block, S.G.P.C., Teja Singh Samundari Hall, Sri Amritsar in the presence of the Bidders or their authorized representative(s) who may wish to be present.

Interested firms can download complete specifications, condition and details of lifts from our website i.e. www.sgpc.net

Chief Secretary,
Shiromani Gurdwara Parbandhak Committee,
Sri Amritsar